



Not to Scale

Item	Each	Description	Specification	Remarks
1	1	Service Saddle	Dbl. Strap w/CS Tap	
2	1	Bronze Corporation Stop	CS inlet x FIP outlet	
3	2	Galvanized 90° Elbow		
4		Galvanized Std. Steel Pipe	Schedule 40	
5	1	Bronze Gate Valve	Ohio Brass No. 2500	
6	1	Galvanized Pipe Plug		
7	1	Concrete Meter Box	Brooks 66 S	

## SAN GABRIEL COUNTY WATER DISTRICT

Approved

General Manager  
S.G.C.W.D. 8366 Grand Ave.  
Rosemead, California

### 2" Blowoff Valve Assembly

Standard  
Dwg. No.

5-A