



Item	Each	Description	Specification	Remarks
1	1	Jones J-3717 Fire Hydrant Assembly		
2	8	Break-off Bolts		
3	1	Bury - c/l - 8 hole Flg x MJ		
4		6" D.I. Pipe - c/l - TJ		
5	1	6" Gate Valve - Flg x MJ		
6	1	Valve Box Assembly		
7		Plastic Cap		
8		Retainer Glands - D.I. - w/set screws		
9	1	D.I. Tee or S.S. Tapping Sleeve		See Plans

# SAN GABRIEL COUNTY WATER DISTRICT

Approved

General Manager  
S.G.C.W.D. 8366 Grand Ave.

STANDARD 6" FIRE HYDRANT ASSEMBLY

Standard  
Dwg. No.

**1A**